

From: Jane Mcallister <applicant>

Sent: 27 February 2026 13:34

To: Tony Young <LB Camden>

Cc: Daniel Koo <daniel koo architects>

Subject: Re: Certificate of Lawfulness (proposed) application - 2026/0687/P - 26-00249-LDCP - 49 Lamble Street

Dear Tony,

My neighbour at No. 12 Barrington Ct (same design as No. 40 Lamble Street) has implemented external insulation on a blockwork build-up (see attached photos).

Build up: In the case of no. 40 Lamble Street, the detail of the buildup will be similar to this: <https://ewipro.com/services/system-build-ups/mineral-wool-insulation-system-build-ups/#mineral-wool-timber-frame>. This will be 90 mm of mineral wool insulation on the ground and first floor and 110-120mm on the new top floor. Both will not exceed the depth of the facing brick piers but will form a drip on top of the bricks. To prevent ingress of water.

Colour: Lime render treated with a breathable paint, which has not been decided, but will be in keeping with the period of the building and colours of the other houses in the terrace.

Hope this helps. If you need further information, please don't hesitate to ask

Kind regards, Jane